

CERTIFICATE OF COMPLIANCE

Certificate Number 20150527-EX26567
Report Reference EX26567-20140728
Issue Date 2015-MAY-27

Issued to: ZIGGIOTTO & C SRL
V.LE DEL LAVORO 4
37055 RONCO ALL'ADIGE,
VERONA ITALY

**This is to certify that
representative samples of**

FIRE HOSE, LINED, UNCOUPLED, FOR MUNICIPAL AND
INDUSTRIAL USE

Single jacketed fire hose, 1-1/2 in. for service test pressures
of 150 and 200 psig and 2-1/2, in. for service test pressure
of 200 psig

Double jacketed fire hose, 1-1/2 and 2-1/2, in. for service
test pressure of 300 psig

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: [ANSI/UL 19](#), "Lined Fire Hose and Hose Assemblies."

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>





Multiple Listing Correlation Sheet

ML FILE NO. EX26567

Issued: 2014-07-28

MULTIPLE LISTING
of
FIRE HOSE, LINED, UNCOUPLED, FOR MUNICIPAL AND INDUSTRIAL USE
(MZQE)
for

[1111025] ZIGGIOTTO & C SRL

Basically Listed for:

[588782] SELEM MATERIAL SCIENTIFIC (JIANGSU) (NBK)
CO LTD

Basically Listed products covered by Procedure and/or Reports under File No. EX6627, Volume 1

Products Covered	Report Date	Basic Applicant's (Supplier's) Product Designation	Multiple Listee's Product Designation
	2004-04-14	Single jacketed fire hose, 1-1/2 in. for service test pressures of 150 and 200 psig and 2-1/2, in. for service test pressure of 200 psig	Single jacketed fire hose, 1-1/2 in. for service test pressures of 150 and 200 psig and 2-1/2, in. for service test pressure of 200 psig
		Double jacketed fire hose, 1-1/2 and 2-1/2, in. for service test pressure of 300 psig	Double jacketed fire hose, 1-1/2 and 2-1/2, in. for service test pressure of 300 psig

MARKING: Same as that described in Follow-Up Service Procedure and/or Report except for Multiple Listee's name, file number, Trademark / Tradename, when applicable, and product designation.

LITERATURE: If literature is packaged with the Multiple Listed product(s) it shall be in compliance with the requirements outlined in the appropriate UL Standard(s).